

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES
Ghosh Para Road, Badamtala, P.O. - Bengal Enamel, P.S.
- Noapara, Pin - 700122**

Memo No : IND/WB/FES/20192020/84888

DATE: 02/03/2020

From :

The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.

To :

DELHI PUBLIC SECONDARY SCHOOL
MOUZA ALGORIA, J.L. NO.-5, DAG NO.-
626, UNDER PASCHIM KHILKAPUR- G.P,
P.S.- BARASAT, DIST. 24 PGS(N).
Barasat F.S., Barasat,
North 24 Parganas - 700124 .

Sub :Fire Safety Certificate for the occupancy of an existing construction of G + III storied building under group Educational at the premises no.- MOUZA ALGORIA, J.L. NO.-5, DAG NO.- 626, UNDER PASCHIM KHILKAPUR- G.P, P.S.- BARASAT, DIST. 24 PGS(N)., Barasat, North 24 Parganas - 700124

This is in reference to your Application No. IND/WB/FES/20192020/84888, dated 02/03/2020, regarding the Fire Safety Certificate for the occupancy of an existing construction of G + III storied building under group Educational at the premises no.- MOUZA ALGORIA, J.L. NO.-5, DAG NO.- 626, UNDER PASCHIM KHILKAPUR- G.P, P.S.- BARASAT, DIST. 24 PGS(N)., Barasat, North 24 Parganas - 700124.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety

measures need to be incorporated / maintained.

1. . Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, Particularly lines above false ceiling & ducts.
5. A fire control room including a closed circuit T.V system will have to be installed which observe all floor of the buildings.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the Building.
7. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
8. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. Transformer and Switch Gear room shall be protected with automatic CO2 or D.C.P. Fire extinction confirming I.S. Specification.
10. A crew of trained Fireman under an experience officer shall be maintained round the clock for safety of the building.
11. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
13. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.

14. Periodical flashing of water in the Hydrants and Sprinkler Pipe line shall be made to maintain the efficiency working performance of above mention system.

15. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.

16. The Head of the organization / Society as the case may be , shall submit a declaration to the Director General ,West Bengal Fire & Emergency Services on every 1st April, 1st July ,1st October,&1st January maintaining financial calendar that "The Fire Prevention and Fire Safety Measures in the building or premises have been tested and are in good working condition. That, no material changes has been done in the building that has affected the means of escape and means of access as the case may be . That, all the members of the organization are well conversant with the evacuation drill and mentally & physically fit to combat the Fire Emergencies. That, any deviation in the above and failure in maintenance of the Fire Prevention and fire safety measures shall at the risk and liability of the Head of the organization/ Society.

This certificate is valid for 3 years from the date of issue and renewable after three years to be obtained from the Director General, West Bengal Fire & Emergency Services for performance of all the life & Fire Safety arrangements and installations of the building failing which this shall be revoked automatically.

1887 / 02/03/2020

Divisional Fire Officer
West Bengal Fire & Emergency Services